



## Test Report

Customer: Inmarco FZC  
P.O. Box 120284  
UAE – SAIF-Zone, P6-50, Sharjah


Project number (amtec): 304 769  
Report number: 304 769 1/-


Test procedure: API Specification 6FB (dated May 2019)

Material: spiral wound gasket – 1K UHT SS316L-SS316L Inn &  
SS316L OUT

Date: October 25<sup>th</sup>, 2021  
Pages: 5  
Appendices: 7

Author: Approval:

  
Dipl.-Ing. F. Herkert  
Head of Laboratory

  
B. Eng. M. Metzger  
Test Engineer

Test results are only relevant to the test objects submitted.

## 1. Subject of Investigation

The following documents and samples were submitted to amtec.

The subject of investigation was a spiral wound gasket manufactured by Inmarco FZC which is customer named:

- INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT.

INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT is a spiral wound gasket with an inner and an outer ring of SS316L. The windings made of SS 316L cover a vermiculite filler material.

## 2. Goal of Investigation

The goal of the investigation was the qualification of the gasket material INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT in accordance to the API Specification 6FB (dated May 2019): API Specification for Fire Test for End Connections.


The API Specification 6FB describes the testing procedure and evaluation of the performance of API end connections when exposed to fire.

### 2.1 Declaration of conformity in the test laboratory of amtec

A declaration of conformity is a written confirmation at the end of a conformity assessment in which the amtec test laboratory for a specific examination bindingly declares and confirms that the product sample has a specified property. The properties are usually specified by limit values in standards, technical specifications or test methods.

For declarations of conformity in the amtec test laboratory the following decision rules have to be considered. The decision rules are explained in an example.

In the following test, a limit value of  $\leq 3$  should be reached.



conformity assessment						√ = pass		x = fail	
measuring points	1	2	3	4	5				
decision rule	√ = pass	√ = pass	x = fail	x = fail	x = fail				

In the example above, measurement points 1 and 2 are a positive conformity statement, the measuring points 3, 4 and 5 are a negative conformity statement.

The standard deviations of the different physical parameters pressure, temperature, and leakage can be found in the protocols of the last maintenance of each test rig.

### 3. Test Specimen

The dimension of the test specimen was: 6" Class 300

Geometry of the gasket: 210.7 mm x 181.3 mm x 4.9 mm

### 4. Testing Equipment

The gasket test was carried out on the following testing equipment in the laboratory of amtec:

Fire Test: TEMES<sub>fire.safe</sub> Ident No. 010595

A photo and the schematic view of the testing equipment are shown in **appendices 1 and 2**.

The Fire Safe Testing Device is used to maintain a fire for a period of 30 minutes.

Depending on the type of test, different flanges and valves can be tested.

For this test the following components were used:

- Blind flanges ASME B 16.5, 6" Class 300, RF / Ra 3,2 - 6,3 µm (125-250 µin), ASTM A 105
- Stud bolt, Grade B7, ASME B18.2.1, ¾" - 10 UNC x 5
- Hexagon nuts, Grade 2H; ASME B18.2.2, ¾" - 10 UNC
- Washers, ¾" hardened 45 HCR

The water pressure is measured by a pressure transducer; the water volume is measured with a scale. The temperature of the fire is measured with 6 different thermocouples and with 5 calorimeters which are shared around the flange or valve. The control of the fire is done by a controller. Software is used for data logging and online evaluation.

## 5. Test Procedure

The Fire Test according to API Specification 6FB (dated May 2019) requires that any sealing end connection hold for 30 minutes in a flame condition and hold for a cool down period. After the assembly is cooled down to room temperature the line is depressurized and then re-pressurized. During all facets of the test the gasket must not exceed an API proscribed leak rate.

In the Fire Test a 6" Class 300 flange is pressurized with a test pressure of 75% of the API rated working pressure. The test pressure is maintained during the burn and cool-down period. After 5 minutes a fire is established and the flame temperature is monitored. The average of the thermocouples must reach 760 °C within 2 minutes and maintain the average temperature between 760 °C to 982 °C with no reading less than 704 °C until the average of the calorimeter temperature reaches 649 °C.

The average of the calorimeter shall reach 649 °C within 15 minutes. The burn period shall last for 30 minutes. After the burn period the connection is air-cooled down to 100 °C or less. After cooling down the flange is depressurized and the pressure is increased again to the test pressure and held for 5 minutes.

The maximum leak rate is 1 ml/inch/min of mean gasket circumference.

## 6. Results

Test date: October 22<sup>nd</sup>, 2021.

In the API Specification 6FB the spiral wound gasket INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT was mounted in a 6" Class 300 flange with hydraulic spanners to a bolt load of 67.17 kN which means a total load of 806 kN and a gasket surface stress of 89.1 MPa.

After that the flange was pressurized with an internal pressure of 40 bar. The test medium was water. After 5 minutes flame impingement starts for a period of 30 minutes, see **appendices 3 to 6**. During burning period the flame temperature was nearly constant. After 30 minutes of burning the flange was cooled down to a temperature less than 100 °C and the system was depressurized and the pressure was increased to 40 bar again.

During burning period a leak rate of 0.02 ml/inch/min could be measured and during complete pressurization with water no leakage could be overserved. During the pressure test after cooldown a leak rate of 0.21 ml/inch/min was measured.


All leak rates are below the allowable leak rate of 1 ml/inch/min and therefore the spiral wound gasket INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT **passed** the Fire Test according to API Specification 6FB dated May 2019.

## 7. Photo documentation

In **appendix 7** photos of the gasket specimen INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT before and after the Fire Test are presented.




**Fire Safe Testing Device**



**Legend**


- |   |   |
|---|---|
| 1. Pressure source                        | 10. Minimum height of enclosure shall be 6 inches above the top |
| 2. Pressure regulator and relief          | 11. Test connection mounted horizontally                        |
| 3. Vessel for water                       | 12. Fuel gas supply   |
| 4. Calibrated sight gauge                 | 13. Calorimeter cubes   |
| 5. Water supply                           | 14. Flame temperature thermocouple                              |
| 6. Shutoff valve                          | 15. Shutoff valve   |
| 7. Pressure gauge                         | 16. Vent valve  |
| 8. Piping arranged to provide vapour trap | 17. Check valve   |

**Schematic System for Fire Testing of End Connections**




**Location of Thermocouples and Calorimeters – Onshore Condition**

Course of Test Fire Safe Test  
 INMARCO 1K UHT SS316L-SS316L Inn & SS316L OUT 22.10.2021 - 89.1 MPa  
 21-346



API Specification 6FB - calorimeters


Course of Test Fire Safe Test  
 INMARCO 1K UHT SS316L-SS316L Inn & SS316L OUT 22.10.2021 - 89.1 MPa  
 21-346



API Specification 6FB – thermocouples




Course of Test Fire Safe Test  
 INMARCO 1K UHT SS316L-SS316L Inn & SS316L OUT 22.10.2021 - 89.1 MPa  
 21-346




API Specification 6FB – thermocouple and calorimeter average

Course of Test Fire Safe Test  
 INMARCO 1K UHT SS316L-SS316L Inn & SS316L OUT 22.10.2021 - 89.1 MPa  
 21-346



API Specification 6FB – medium and flange

Course of Test Fire Safe Test  
 INMARCO 1K UHT SS316L-SS316L Inn & SS316L OUT 22.10.2021 - 89.1 MPa  
 21-346



**API Specification 6FB – pressure test**

**Fire Safe Test 21-346 INMARCO 1K UHT SS316L-SS316L Inn &  
SS316L OUT****geometries of gasket and flanges**

bolts	12
OD gasket	210.7 mm
ID gasket	181.3 mm
height gasket	4.9 mm
material gasket	1K UHT SS316L
mean gasket circumference total	615.9 mm
contact area total	9050.09 mm <sup>2</sup>
OD flange raised face (NPS 6 Class 300)	215.9 mm
<b>leak rate criteria</b>	<b>1 ml / inch / min</b>

**test conditions**

testrig	TEMES fire.safe
name	010595
test procedure	API Specification 6FB
dated	05/2019

**bolts, nuts, washers**

type of bolts	3/4" - 10 UNC
nuts	3/4" - 10 UNC
grade	B7
washers	3/4" hardened 45 HCR

**calculation of gasket stress**

hydraulic mounting device	
force per bolt	67.17 kN
force total	806.00 kN
<b>gasket stress sealing element</b>	<b>89.06 MPa</b>

**calculation of leak rate of complete test**


start value scale	29.04 kg
end value scale	29.03 kg
start test	09:01:15
end test	12:00:35
test duration (min)	179.32 min
leakage	12.60 ml
<b>leak rate</b>	<b>0.00 ml / inch / min</b>
<b>requirement</b>	<b>passed</b>

**calculation of leak rate of burning period**

start value scale	29.04 kg
end value scale	29.03 kg
start test	09:01:15
end test	09:31:15
test duration (min)	30 min
leakage	12.60 ml
<b>leak rate burning period</b>	<b>0.02 ml / inch / min</b>

**calculation of leak rate of pressure test after cooldown**

start value scale pressure test	29.24 kg
end value scale pressure test	29.21 kg
start pressure test	12:08:16
end pressure test	12:13:16
test duration (min)	5 min
leakage	25.30 ml
<b>leak rate pressure test</b>	<b>0.21 ml / inch / min</b>
<b>requirement</b>	<b>passed</b>



**INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT before testing**



**INMARCO - 1K UHT SS316L-SS316L Inn & SS316L OUT after Fire Test 21-346 according to API Specification 6FB**